

**SET
CONFIG.**

P START
bar/psi

1



2



3



**PREVIEW
VISUALIZAR
VEDERE
VISUALISER**

P START
bar/psi



**SET
CONFIG.**

P STOP
bar/psi

1



2



3



**PREVIEW
VISUALIZAR
VEDERE
VISUALISER**

P STOP
bar/psi



SETTINGS - AJUSTES - PROGRAMMATION - CONFIGURAZIONE

1		
2		
* 3		
4		
** 5		
6		
*** 7		
	sB0=OFF / sB1=ON	
8		
9		

* **rc**: ALARM A04

*** **sB**: STAND-BY MODE - MODO AHORRO
MODALITÀ STANDBY - MODE VEILIE

** **XX**: **sec** START1
r01÷r99 seconds
START2

ALARMS - ALARMAS - ALLARMI - ALARMES

CODE

A01

SW2

DRY-RUN
FUNCIONAMIENTO EN SECO
MARCHÉ À SEC
FUNZIONAMENTO A SECCO



A11

SW1/2/3

DRY-RUN BY MIN. PRESSURE
FALTA DE AGUA POR P.MIN
MARCHÉ À SEC PAR P.MIN
MANCANZA D'ACQUA PER P.MIN



A02

SW2

OVERLOAD
SOBREINTENSIDAD
SURINTENSITÉ
SOVRAINTENSITÀ



A04

SW1/2/3

FAST CYCLING
CICLOS RÁPIDOS
ÉTAT DE CYCLE RAPIDE
CICLI ECCESSIVI



A05

SW1/2/3

DAMAGED PRESSURE SENSOR
TRANSDUCTOR AVERIADO
CAPTEUR DE PRESSION EN PANNE
TRASDUTTORE GUASTO



~1x48÷230Vac/Vdc (SW3)
~1x110÷230Vac (SW1/2)

Risk by electric shock.
Riesgo por descarga eléctrica.
Risque de choc électrique.
Rischio di scosse elettriche.



ONLY
SÓLO
SEULEMENT
SOLO

outlet alarms
salida alarmas
sortie alarmes
uscita alarmi

MAX. 230VAC / 30W

SW1/2

SW3

N

C1 C2

SWITCHMATIC 2A/3A

DATA - DATOS - DONNÉES - DATI

 2,2 kW (SW1/2)	 •16 A (SW1/2) •cos fi≥0,6 •10A (SW3)	 60°C environment ambiente environnement	 1÷8 bar stop
 ~1x110÷230Vac (SW1/2) ~1x48÷230Vac/Vdc (SW3)	 IP 55	 G 1/4" FEM.	 7,5 bar max.
 50/60 Hz	 50°C water/agua/eau/acqua	 0,5÷7 bar start	 0,5 bar min.

**MANUAL
START**

Pump
Bomba
Pompe
Pompa } **ON**



SET OVERLOAD PROTECTION
CONFIGURAR PROTECCIÓN CONTRA SOBREINTENSIDAD
CONFIGURATION DE LA PROTECTION CONTRE LES SURINTENSITÉ
CONFIGURAZIONE PROTEZIONE CONTRO SOVRAINTENSITÀ
(ONLY/SÓLO/SOLO/ SEULEMENT SWITCHMATIC 2)

